



UNIFORM CITATION
Code Enforcement

8100 Ewing Blvd, Florence, KY
859-647-5416
www.florence-ky.gov

LOCATION OF VIOLATION
7690 Burlington Pike
NAME
Speedway
MAILING ADDRESS
7690 Burlington Pike
Florence KY, 41042

DEPARTMENT
Florence Fire/EMS
DATE ISSUED
3/3/2023
VIOLATION DATE
3/3/2023

CITATION NUMBER
RSC-2023-01
TIME ISSUED
1500
VIOLATION TIME
1500

Total due balances are not carried forward. If you receive two or more citations, balance is due for EACH citation.

Table with 3 columns: ORDINANCE NO., VIOLATION TYPE, CIVIL FINE PER VIOLATION. Contains 7 rows of violation data and a total due row for \$100.00.

DESCRIPTION OF VIOLATION(S)
1. Exit doors are locked during operational hours.
2. Exit doors are blocked by sales displays.

OFFICIAL'S SIGNATURE (handwritten), OFFICIAL'S NAME: Randy Childress, PHONE #: 859-647-5660

CITATION SERVICE TYPE: [X] Posted on Premises & Copy Mailed
CITATION ACCEPTED BY:
DELIVERY COMMENTS:

Maximum civil fine that may be imposed per violation if this citation is contested: \$500.00

This citation represents a determination that a violation has been committed. You must respond to this citation within seven (7) days of the date issued by either paying the civil fine set forth in the citation, or requesting, in writing, a hearing to contest the citation.

CONTESTING THE CITATION

A written request for a hearing to contest the citation must be made within seven (7) days of the date issued. Such request for hearing shall be filed in the office of the Florence City Clerk, 8100 Ewing Boulevard, Florence, KY 41042.



# Florence Fire-EMS



Occupancy: **SPEEDWAY**  
Occupancy ID: **BURLINGTON-7690**  
Address: **7690 BURLINGTON PIKE**  
**FLORENCE KY 41042**

Inspection Type: **Complaint**

Inspection Date: **3/2/2023**

By: **CHILDRESS, RANDY (0000-7946/1032330)**

Time In: **17:00**

Time Out: **17:00**

Authorized Date: **03/02/2023**

By: **CHILDRESS, RANDY (0000-7946/1032330)**

Next Inspection Date: **03/05/2023 Reinspection**

Form: 2022 Inspection Form

## Inspection Description:

This form should be used for general inspections, re-inspections, occupational license and certificate of occupancy inspections.

## Inspection Topics:

### Exits

Are corridors and aisles of the exit pathway clear of obstructions?

Exit pathways must remain clear of obstructions and be available for use in case of emergencies anytime a building is occupied. NFPA 1.14.4 Means of Egress Reliability. NFPA 1: Fire Code, 2018 Edition. NFPA (© 2017)

**Status: VIOLATION NOT CORRECTED**

**Notes: Exit blocked by sales display must be clear of obstructions.**





Are exits available for immediate use?

Exits must remain available for immediate use anytime a building is occupied. Occupants must be able to use the nearest exit regardless of their location in a building. NFPA 1.14.4 Means of Egress Reliability. NFPA 1: Fire Code, 2018 Edition. NFPA (© 2017)

**Status:** VIOLATION NOT CORRECTED

**Notes:** Exit blocked by sales display must be available for immediate use while building is occupied.



### Misc Violations

Other code or safety violations found?

NFPA 1.4.5 General Requirements. NFPA 1: Fire Code, 2018 Edition. NFPA (© 2017)

**Status:** VIOLATION NOT CORRECTED

**Notes:** The facility must be maintained as approved for the initial certificate of occupancy. Elimination of an exit is not permitted without a redesign and evaluation of the building.

### Additional Time Spent on Inspection:

Category	Start Date / Time	End Date / Time
<b>Notes:</b> No Additional time recorded		

**Total Additional Time: 0 minutes**

**Inspection Time: 0 minutes**

**Total Time: 0 minutes**

### Summary:

**Overall Result:** Third Correction Notice - Referred to City Fire Marshal

**Inspector Notes:** Hard copy will be dropped off to business.

### Closing Notes:

Florence Fire/EMS has completed a life safety/fire inspection of your facility. If violations were noted then these conditions are contrary to law and must be corrected upon receipt of this notice. A date will be scheduled to re-inspect the noted violations. If no violations were noted then no further action is necessary. Thank you for your cooperation. If you have further questions or comments please contact the Florence Fire/EMS Fire Marshal at 859-647-5660.

**Inspector:**

Name: CHILDRESS, RANDY  
Rank: BC  
Email(s): Randy.Childress@florence-ky.gov



Signature

3/2/2023

Date

**Representative Signature:**

Signature

Date

